



*Airborne Labs International*


22C World's Fair Drive Somerset, NJ 08873 T: 732-302-1950 F: 732-302-3035  
E-mail: Sales@airbornelabs.com Website: www.airbornelabs.com

# H<sub>2</sub> Fuel Type I Grade D\* Sampling & Analysis ISO-14687:2019 (E) Product Specs

*Presented at the International  
Technical Cleanliness Forum & EXPO  
"Parts4Assembly"*

*May 2023*

\* Gaseous H<sub>2</sub>: FCEV Fuel Cells for road vehicles



**Mark Taylor, Don Pachuta Ph.D., & Chandler Stryker**

# Why Test H<sub>2</sub> Fuel?



- Impurities in H<sub>2</sub> Fuel can reduce vehicle efficiency and potentially cause **permanent, expensive** fuel cell damage
- It is the responsibility of the **H<sub>2</sub> Fuel supplier** to identify, measure, and control the levels of impurities listed in the ISO/SAE guidelines to deliver an appropriate ISO/SAE H<sub>2</sub> fuel Grade Product for customer end use
- **TRUST BUT VERIFY.** It is also a responsibility of the **Fuel Station owner and Government** to ensure that the H<sub>2</sub> fuel stored and delivered to customers meets ISO/SAE Purity standards for the intended transport vehicle application.



*The Critical Step in ALL H<sub>2</sub> Purity Test Programs is to ensure that a representative H<sub>2</sub> Fuel sample is taken and preserved until analyzed.*

## 3 Key Aspects of an ISO/SAE H<sub>2</sub> Fuel Quality Program

- Representative Sampling
- Safe & Proper Hazmat Shipping
- Proper ISO-17025 Laboratory Analysis for Critical Impurities

*Future Goal = Rapid, On-Site Analysis at H<sub>2</sub> Fuel Manufacturers and Fueling Facilities*



# ISO / SAE Type I, Grade D Purity Specifications & Analytical Methods

Parameter	Guideline Limit	Method
Hydrogen Fuel Index (H <sub>2</sub> Purity):	99.97 % v/v min.	
Total Non-Hydrogen Gases:	300 ppm v/v max.	
Maximum Concentration of Individual Contaminants		
Water (H <sub>2</sub> O):	5 ppm v/v max.	ASTM D7653, D7649, D7941, D7941M
Total Non-Methane Hydrocarbons (TNMHC; C <sub>1</sub> Equivalent):	2 ppm v/v max.	ASTM D7675, D7833
Oxygen (O <sub>2</sub> ):	5 ppm v/v max.	ASTM D7649, D7607
Methane (CH <sub>4</sub> ):	100 ppm v/v max.	ASTM D7653, D7675, D7833, D5466
Helium (He):	300 ppm v/v max.	ASTM D7833
Nitrogen (N <sub>2</sub> ):	300 ppm v/v max.	ASTM D7649, D7833
Argon (Ar):	300 ppm v/v max.	ASTM D7833
Carbon Dioxide (CO <sub>2</sub> ):	2 ppm v/v max.	ASTM D7649, D7653, D7833
<b>Carbon Monoxide<sup>b</sup>(CO):</b>	0.2 ppm v/v max.	ASTM D7653
<b>Total Sulfur Compounds<sup>c</sup> (TSC):</b>	0.004 ppm v/v max.	ASTM D7652, D6228
Formaldehyde (HCHO):	0.2 ppm v/v max.	ASTM D7653, D7941, D7892
Formic Acid (HCOOH):	0.2 ppm v/v max.	ASTM D7653
<b>Ammonia (NH<sub>3</sub>):</b>	0.1 ppm v/v max.	ASTM D7653, D9741/D7941M
<b>Halogenated Compounds (Halogen Ion Equivalent)<sup>d</sup>:</b>	0.05 ppm v/v max.	ASTM D7892, D7676, D5466
Particulate Concentration	1 mg/kg	ASTM D7650, D7651

H<sub>2</sub> Fuel Impurity Profiles are **highly Feed Source Dependent**

Some impurities are introduced via transport / storage and dispensing (**contaminants**)

Some impurities cause **temporary** damage to a FCEV Cell

Some Impurities cause **permanent** damage to a FCEV Cell



# Current Methods of H35 / H70 Station Sampling

## Gaseous Impurities – Sampling Protocols

A) “Gas Serial” type methods (Sample H35/70 Pumps). Some types **Do not** require a ½ filled FCEV Vehicle for sampling OR a **large** truck mounted >55L tank). Some models just require the **Manual Pump** Mode @ fixed Pressure with station **venting to Atm.**

- **Method 1: ASTM D7606-17:** (ex. NSP-7606 / JSM-7606. Passivated hardware, 1L x **2-valve** passivated ss cylinder purge / fill. **Manual pump mode Only.** Accessories for on-site Detector Tube tests / H<sub>2</sub>O / O<sub>2</sub> analyzers + other analytical sensors, JSM-7606 model for sampling of H35/H70 stations

OR

FCEV vehicle tanks, storage tanks, transfer lines, tube trailer applications. Minimal cylinder treatment needed with lab-based prep/testing. All units stored in a **portable case** for easy field transport & shipping.



# Current Methods of H35 / H70 Station Sampling

## Gaseous Impurities – “Gas Serial” Sampling Protocols (Cont’d)

- **Method 2** (Table mounted, non-passivated hardware, 5L x 2-valve Al cylinder). Accessories for On-Site H<sub>2</sub>O / O<sub>2</sub> analyzer testing). **Manual pump mode Only.**
- **Method 3:** ISO19880-1 Annex K. Employs **EITHER** a ½ filled FCEV vehicle (& **Auto-mode**) or **No FCEV vehicle/Tank & Manual** mode apps. Uses **1-Valved, large 46.7L Polished, 1-Valved Manganese Steel Cylinder** (initially evacuated – then filled-flushed-filled several times).
- **Method 4:** Pumps can **EITHER** be in **Auto Mode** with a **55L** cylinder to **simulate** a FCEV vehicle or **Manual Mode**. Accessories can allow connected H<sub>2</sub>O/O<sub>2</sub> etc. on-site analyzers.

**Vehicle manufacturers have recently stated FCEV use during Auto-Mode H<sub>2</sub> sampling is not acceptable - as filling an FCEV with potentially contaminated H<sub>2</sub> may cause permanent cell damage.**

**Therefore, use of the pump’s Auto-Mode for H<sub>2</sub> sampling will mandate use of a large Ballast tank to simulate the FCEV filling process.**



# Current Methods of H35 / H70 Station Sampling

## Gaseous Impurities – Sampling Protocols (Cont'd)

**B. “Gas Parallel” type methods** (Requires either a ½ filled FCEV Vehicle or a large ballast tank ex. **55+L for sampling**). H35/70 Pumps can be in Auto Mode or Manual Mode. Sample cylinder in parallel line to Vehicle via **T-fitting**.

- **Method 5: ISO19880-1** (10L x **1-Valve** AL cylinder. Extensive cylinder preparation / multiple purging protocols). **Requires** a ½ filled FCEV vehicle or large ballast tank & Auto-Mode.
- **Method 6: ISO19880-1 + SAE J2601**. Can be used **with / without** ½ filled FCEV Vehicle or large buffer tank. **Auto or Manual** Sample Pump mode. 3 modules. 10L 1-valve Al cylinders or up to 3 x 2.5 – 10L x 2-valved cylinders. Extensive cylinder preparation and protocol.

**Vehicle manufacturers have recently stated FCEV use during Auto-Mode H<sub>2</sub> sampling is not acceptable - as filling an FCEV with potentially contaminated H<sub>2</sub> may cause permanent cell damage.**

**Therefore, use of the pump's Auto-Mode for H<sub>2</sub> sampling will mandate use of a large Ballast tank to simulate the FCEV filling process.**




# ALI H<sub>2</sub> Fuel Sampling / Shipping Kit (used with NSP/JSM-7606 + MSM-7650) Samplers)

- 2 x 1L Silconert™ Passivated Cylinders
- 2 x VHP Particulate SS 47 mm Filter Assemblies\*

\*(45 mm PTFE x 0.2 um PTFE/PE Filter Patches + Frit Backing)

End-capped &  
ID Tag Labeled  
Filter Assy in  
Anti-static bag




Small, rugged  
shipping case.





# H<sub>2</sub> Fuel Sampling - 1L Cylinder


- All gas wetted parts are **Silconert™** passivated to prevent trace impurity wall absorption by active analytes (ex. TSC) + longer life in H<sub>2</sub> service.
- Passivated high quality needle valves with wide seat base.
- Lanyard End-Capped, **Quick Connect** inlet / Outlet valves for NSP / JSM – 7606 Sampler coupling
- 1900 psig (129 bar) Pressure Relief Combination Valve.
- DOT or Pi marked Cylinder bodies.
- Small US Football size for easy transport & air shipping
- Sample Filled to 1,000 psig (68 bar). Many replicate analyses can be performed with this sample size.
- Simple, rapid cylinder prep & on-site purging protocol



# H<sub>2</sub> Sampling Kit

## Particulate (NVR) VHP SS Filter Housing

(Easily field exchangeable for Multiple Fuel Station Sampling)



Pre-Weighed, 47mm Filter PTFE  
x 0.2 um Filter Patches + backing  
Installed as per ASTM D7650  
Method



# Current Methods of H35 / H70 Station Sampling

## Particulate Impurities; (ex. Non-Volatile Residues (NVR))\* by ASTM D7650-21

- **A)** Weighed 0.2  $\mu\text{m}$  x 47mm PTFE Filter patch + sampled  $\text{H}_2$  wt **calculated** from pressure / temp measurement from a **v. large (55+L) truck-mounted ballast tank**.
- **B)** Weighed Filter patch plus total sampled  $\text{H}_2$  kg wt needed for mg/kg  $\text{H}_2$  wt measurement is **precisely determined** with by a Coriolis **Mass Flow Meter (MFM)** in **Totalizer Mode** (ex. MRM-7650).

Flow rate typically 10 – 20 g/sec.



Typical FCEV Fuel Tank



\*Ex. wear metals, dirt, dust, elastomeric debris, grease, oils



# H<sub>2</sub> Sampling Platforms

## NSP 7606, JSM-7606\* & MRM 7650



**NSP-7606** for Gaseous Impurities



**MRM-7650 + MFM Totalizer Module** for Particulates (NVR)

\*Model **JSM-7606** similar to NSP model but designed for sampling **either** H<sub>2</sub> Fuel Stations or H<sub>2</sub> Storage Tanks **or** Sample Lines / Tube Trailers



# Proper H35/H70 H<sub>2</sub> Sampling Protocol

Whenever BOTH Gaseous impurities AND Particulates (NVR) must be sampled:

- **ALWAYS** perform Particulate sampling 1<sup>st</sup> – followed by Gaseous Impurities sampling 2<sup>nd</sup>

## WHY?

- NVR is typically **NOT** distributed homogeneously throughout the H<sub>2</sub> gas phase as volatile gaseous impurities & contaminants will be.
- Typically NVR materials are heterogeneously\* surface located (mainly on the interior surface walls) throughout the pump's hardware during a static H<sub>2</sub> gas phase period.

\* Because of this physical factor - the **reproducibility** of replicate NVR samples should **not** be expected.

In theory then the 1<sup>st</sup> NVR sample taken will **most likely be** much **higher** than subsequent replicate NVR samples.

*NVR sampling is most typical for new stations or after station maintenance actions*




# H<sub>2</sub> Fuel Sampling for NVR by MRM-7650

- Designed to sample for NVR **directly** from H35/H70 dispenser nozzles
- Uses a rugged Mass Flow Meter (MFM) with a **Totalizer** for precise and accurate measurement of total H<sub>2</sub> mass & volume sampled.
- Ideal for rapid (<10 min) station sampling
- Fully meets ASTM D-7650-21 requirements for H35/H70 particulate (NVR) sampling.
- Max MFM Flow  $\approx$  120 g/sec
- Typical Sampling Flow 10 - 20 g/sec




# MRM-7650 Gas Flow Diagram - Overview



# MRM-7650 H<sub>2</sub> Fuel NVR Sampling

## BASIC SAMPLING STEPS – Overview

- 1) Place Station Dispenser in **Manual Mode**
- 2) Connect the MRM Ground Wire, MRM Vent line, Pump Nozzle & connect MRM Control Module
- 3) Pressurize to  $\approx 2,500$  psig (170 bar) & Slowly Open V1 plus **leak check** from Nozzle to closed V2. (note: If a leak is found the system must be shut down / depressurized & a new Filter Assy installed).
- 4) Close V1 – Step Pressure up to  $\approx 5,000$  psig (340 bar) then **Slowly** Open V1 and leak check **again** (note: If a leak is found the system must be shut down / depressurized & a new Filter Assy installed).
- 5) Crack Open V2 **slightly** to allow H<sub>2</sub> to enter MFC – then **quickly** Close V2
- 6) Turn on / **Zero** the Control Module **kg Totalizer with CV crack pressure 10 psig (0.7 bar) residual H<sub>2</sub>**.
- 7) Start MCM / Slowly Open V2 until  $\approx 15$  g/sec flow is reached –then monitor the **kg of H<sub>2</sub>** being sampled.
- 8) When 2+ kg H<sub>2</sub> **minimum** is sampled – **close** V1 (the MRM will depressurize to minimum CV crack pressure ).
- 9) **Depressurize** the Nozzle Source & Close V2.
- 10) Remove / Cap the **Filter Assy + add kg H<sub>2</sub> Sampled\*** To its ID label.



\*Note MFM Totalizer data should be compared to Station Dispenser's "**kg Delivered**" Value they should closely match.






# Gaseous Impurity Sampling


- Gaseous impurities / contaminants should be **homogeneously distributed** in the H<sub>2</sub> Fuel
- Sampling for **Only** Gaseous impurities is **most common** in H35/H70 applications
- Described are 2 Sampler Models: NSP-7606 and JSM-7606 for H35/H70 and many other Sampling applications



# NSP-7606 Gas Flow Plumbing - Overview




Vent to Atm.



For Line Depressurization Or Connect to DT Test Rig / Portable Analyzers / FCEV tank Sampling Accessories



## JSM-7606 Gas Flow Plumbing - Overview



Versatile – for Multiple Types of H<sub>2</sub> Fuel Sampling

Ex. H35/H70, Pipelines, Storage Tanks, In-Process Mfg., Tube Trucks, FECV's

\*For Line Depressurization or DT Test Rig / Portable Analyzers / FCEV Tank Sampling Accessories



# H<sub>2</sub> Fuel Sampling by NSP-7606 System

- BASIC SAMPLING STEPS – Overview

- 1) Place Station Dispenser in **Manual** Mode
- 2) **Connect** the NSP Ground Wire, NSP Vent line & Pump Nozzle
- 3) **Pressurize** Pump to ≈2,500 psig (170 bar) & Set the NSP Pressure Regulator to 1,000 psig (68 bar) & H<sub>2</sub> Leak Test.
- 4) **Purge** Both Entire Platform Paths
- 5) **Purge** The 1L Cylinder
- 6) **Fill** the Cylinder to 1,000 psig (68 Bar) & Close Both Cyl Valves
- 7) **Depressurize** the pump Nozzle & NSP Platform
- 8) **Disconnect** / Label / Store the 1<sup>st</sup> 1L Cylinder
- 9) **Repeat** Process with the 2<sup>nd</sup> replicate cylinder



# Proper Return of H<sub>2</sub> Fuel Samples (Hazmat Shipment) to ISO-17025 Analytical Lab

Overpack Ship Case

End-capped/ID Tagged Sample Filter Assembly in Anti-static Shipping Bag



Analysis Authorization Form									
1. REPORT RESULTS TO: Please attach complete label information. Attach the following label to pertinent units and file in completed and returned.									
COMPANY:	Name			City	State	Zip	Phone #		
ADDRESS:									
CONTACTS:									
EMAIL ADDRESS(ES):									
TELEPHONE:	INVOICE # OR QUOTE #				SECURITY TAG NUMBER:				
P.O.#:	CREDIT CARD TYPE:				Credit Card Type				
SAMPLED ON (IMMEDIACY):	CREDIT CARD NUMBER & EXP. DATE								
2. INDICATE HOW YOUR SAMPLE SHOULD BE IDENTIFIED & ATTACHED TO FOR MULTIPLE SAMPLES:									
# OF SAMPLES TAKEN:									
CONTAINER TYPES:	COSMOGENE			GAS SAMPLING BAGS:			MIRACLES:		OTHER:
	HYDROGEN CYLINDER:			STD. ALL-NO-HAZ. SAMPLING KIT:					
	LIN	PROPANE	AVIATOR BREATHING O <sub>2</sub> /N <sub>2</sub> O				HELIUM		
	LOX	AIR	NATURAL GAS				NEON / HELIUM / ARGON		
	LAR	OXYGEN	ARGON				USE SEPARATE SERVICE VESSEL		
	RELON	NITROGEN	HYDROGEN				OTHER:		
3. SAMPLE TYPE:	INDUSTRIAL			OTHER:			OTHER:		
	METAL:			OTHER:					
4. POTENTIAL HAZARDS: Please specify any hazards.									
5. ANALYTICAL PROGRAM OR INDIVIDUAL TESTS REQUESTED: STD. HANDLING PRECAUTIONS: OTHER PRECAUTIONS:									
6. OTHER: Please send all relevant test results: CH <sub>4</sub> , CO, H <sub>2</sub> , H <sub>2</sub> O, H <sub>2</sub> S, NH <sub>3</sub> , N <sub>2</sub> O, O <sub>2</sub> , SO <sub>2</sub> , NO <sub>x</sub> , CO <sub>2</sub> , H <sub>2</sub> CO <sub>3</sub> , H <sub>2</sub> SO <sub>4</sub> , H <sub>2</sub> PO <sub>4</sub> , H <sub>2</sub> PO <sub>3</sub> , H <sub>2</sub> PO <sub>2</sub> , H <sub>2</sub> PO, H <sub>2</sub> PO <sub>1</sub> , H <sub>2</sub> PO <sub>0</sub> , H <sub>2</sub> PO <sub>-1</sub> , H <sub>2</sub> PO <sub>-2</sub> , H <sub>2</sub> PO <sub>-3</sub> , H <sub>2</sub> PO <sub>-4</sub> , H <sub>2</sub> PO <sub>-5</sub> , H <sub>2</sub> PO <sub>-6</sub> , H <sub>2</sub> PO <sub>-7</sub> , H <sub>2</sub> PO <sub>-8</sub> , H <sub>2</sub> PO <sub>-9</sub> , H <sub>2</sub> PO <sub>-10</sub> , H <sub>2</sub> PO <sub>-11</sub> , H <sub>2</sub> PO <sub>-12</sub> , H <sub>2</sub> PO <sub>-13</sub> , H <sub>2</sub> PO <sub>-14</sub> , H <sub>2</sub> PO <sub>-15</sub> , H <sub>2</sub> PO <sub>-16</sub> , H <sub>2</sub> PO <sub>-17</sub> , H <sub>2</sub> PO <sub>-18</sub> , H <sub>2</sub> PO <sub>-19</sub> , H <sub>2</sub> PO <sub>-20</sub> , H <sub>2</sub> PO <sub>-21</sub> , H <sub>2</sub> PO <sub>-22</sub> , H <sub>2</sub> PO <sub>-23</sub> , H <sub>2</sub> PO <sub>-24</sub> , H <sub>2</sub> PO <sub>-25</sub> , H <sub>2</sub> PO <sub>-26</sub> , H <sub>2</sub> PO <sub>-27</sub> , H <sub>2</sub> PO <sub>-28</sub> , H <sub>2</sub> PO <sub>-29</sub> , H <sub>2</sub> PO <sub>-30</sub> , H <sub>2</sub> PO <sub>-31</sub> , H <sub>2</sub> PO <sub>-32</sub> , H <sub>2</sub> PO <sub>-33</sub> , H <sub>2</sub> PO <sub>-34</sub> , H <sub>2</sub> PO <sub>-35</sub> , H <sub>2</sub> PO <sub>-36</sub> , H <sub>2</sub> PO <sub>-37</sub> , H <sub>2</sub> PO <sub>-38</sub> , H <sub>2</sub> PO <sub>-39</sub> , H <sub>2</sub> PO <sub>-40</sub> , H <sub>2</sub> PO <sub>-41</sub> , H <sub>2</sub> PO <sub>-42</sub> , H <sub>2</sub> PO <sub>-43</sub> , H <sub>2</sub> PO <sub>-44</sub> , H <sub>2</sub> PO <sub>-45</sub> , H <sub>2</sub> PO <sub>-46</sub> , H <sub>2</sub> PO <sub>-47</sub> , H <sub>2</sub> PO <sub>-48</sub> , H <sub>2</sub> PO <sub>-49</sub> , H <sub>2</sub> PO <sub>-50</sub> , H <sub>2</sub> PO <sub>-51</sub> , H <sub>2</sub> PO <sub>-52</sub> , H <sub>2</sub> PO <sub>-53</sub> , H <sub>2</sub> PO <sub>-54</sub> , H <sub>2</sub> PO <sub>-55</sub> , H <sub>2</sub> PO <sub>-56</sub> , H <sub>2</sub> PO <sub>-57</sub> , H <sub>2</sub> PO <sub>-58</sub> , H <sub>2</sub> PO <sub>-59</sub> , H <sub>2</sub> PO <sub>-60</sub> , H <sub>2</sub> PO <sub>-61</sub> , H <sub>2</sub> PO <sub>-62</sub> , H <sub>2</sub> PO <sub>-63</sub> , H <sub>2</sub> PO <sub>-64</sub> , H <sub>2</sub> PO <sub>-65</sub> , H <sub>2</sub> PO <sub>-66</sub> , H <sub>2</sub> PO <sub>-67</sub> , H <sub>2</sub> PO <sub>-68</sub> , H <sub>2</sub> PO <sub>-69</sub> , H <sub>2</sub> PO <sub>-70</sub> , H <sub>2</sub> PO <sub>-71</sub> , H <sub>2</sub> PO <sub>-72</sub> , H <sub>2</sub> PO <sub>-73</sub> , H <sub>2</sub> PO <sub>-74</sub> , H <sub>2</sub> PO <sub>-75</sub> , H <sub>2</sub> PO <sub>-76</sub> , H <sub>2</sub> PO <sub>-77</sub> , H <sub>2</sub> PO <sub>-78</sub> , H <sub>2</sub> PO <sub>-79</sub> , H <sub>2</sub> PO <sub>-80</sub> , H <sub>2</sub> PO <sub>-81</sub> , H <sub>2</sub> PO <sub>-82</sub> , H <sub>2</sub> PO <sub>-83</sub> , H <sub>2</sub> PO <sub>-84</sub> , H <sub>2</sub> PO <sub>-85</sub> , H <sub>2</sub> PO <sub>-86</sub> , H <sub>2</sub> PO <sub>-87</sub> , H <sub>2</sub> PO <sub>-88</sub> , H <sub>2</sub> PO <sub>-89</sub> , H <sub>2</sub> PO <sub>-90</sub> , H <sub>2</sub> PO <sub>-91</sub> , H <sub>2</sub> PO <sub>-92</sub> , H <sub>2</sub> PO <sub>-93</sub> , H <sub>2</sub> PO <sub>-94</sub> , H <sub>2</sub> PO <sub>-95</sub> , H <sub>2</sub> PO <sub>-96</sub> , H <sub>2</sub> PO <sub>-97</sub> , H <sub>2</sub> PO <sub>-98</sub> , H <sub>2</sub> PO <sub>-99</sub> , H <sub>2</sub> PO <sub>-100</sub> .									
7. SAMPLE DISPOSITION: Complete and do not leave for 3 business days after report distribution unless otherwise noted.									
8. RETURN TO: Please indicate what you'll like ALI to do with your sample after testing.									
9. RETURN TO: Please indicate how quickly you would like your test results reported.									

Analysis Request Authorization Form

Security Tags



# NSP / JSM-7606 + MRM-7650 Portability / Shipping Packages

Easily Portable  
NSP or JSM or MRM  
Samplers in their  
Own Rugged  
Transport Case




Properly  
HazMat-Labeled ALI  
H<sub>2</sub> Fuel Sampling Kit



# ISO 14687:2019 SAE J2719 COA Report

Reports are Locked and Sealed to prevent potential data tampering



## Hydrogen (H<sub>2</sub>) ISO 14687:2019 Fuel Analysis Report

Customer:  
Address:  
Phone:  
Attn.:  
Email:

ALI Track No.:  
Received On:  
Report Date:  
Invoice No.:

Sample ID: Compressed, Gaseous H<sub>2</sub> Fuel @ H70 Dispenser Nozzle  
 Sample ID: Received in 2 x 1L passivated ALI cylinders + VHP Filter Patch Kit

Date Sampled:

**Test Description/Units**

Result	Spec
Hydrogen Fuel Index (H <sub>2</sub> , % Purity v/v by Subtractive Diff.):	99.97 min
<b>Total Non-Hydrogen, Non-Helium Gases (ppm v/v):</b>	300 max
<b>Water Vapor (H<sub>2</sub>O, ppm v/v):</b>	5 max
<b>Total Non-Methane Hydrocarbon Content (TNMHC, ppm v/v as CH<sub>4</sub>):</b>	2 max
<b>Oxygen (O<sub>2</sub>, ppm v/v):</b>	5 max
<b>Methane (CH<sub>4</sub>, ppm v/v):</b>	100 max
<b>Helium (He, ppm v/v):</b>	300 max
<b>Nitrogen (N<sub>2</sub>, ppm v/v):</b>	300 max
<b>Argon (Ar, ppm v/v):</b>	300 max
<b>Carbon Dioxide (CO<sub>2</sub>, ppm v/v):</b>	2 max
<b>Carbon Monoxide (CO, ppm v/v):</b>	0.2 max
<b>Total Sulfur Content (TSC, ppb v/v as H<sub>2</sub>S):</b>	4 max
<b>Formaldehyde (CH<sub>2</sub>O, ppm v/v):</b>	0.2 max
<b>Formic Acid (CHOOH, ppm v/v):</b>	0.2 max
<b>Ammonia (NH<sub>3</sub>, ppm v/v):</b>	0.1 max
<b>Total Halogenates (VXC + Inorganics, ppm v/v as X):</b>	0.05 max
<b>Particulates (Non-volatile Residue, ppm w/w):</b>	1

Comments: Positive Identification by GC, LOQ = less than 1, MDL = less than 0.01  
 Comments: (LOQ = 1, MDL = 0.5)  
 Comments: LOQ = 1, MDL = 0.5  
 Comments: LOQ = 0.2, MDL = 0.1  
 Comments: LOQ = 1, MDL = 0.5  
 Comments: LOQ = 0.1, MDL = 0.05  
 Comments: LOQ = 20, MDL = 10  
 Comments: LOQ = 1, MDL = 0.5  
 Comments: LOQ = 0.1, MDL = 0.05  
 Comments: LOQ = 0.1, MDL = 0.05  
 Comments: LOQ = 0.5, MDL = 0.25 ppb each target VSC analyte  
 Comments: LOQ = 0.02, MDL = 0.01  
 Comments: LOQ = 0.25, MDL = 0.1  
 Comments: LOQ = 0.02, MDL = 0.01  
 Comments: X = Cl, Br, I, F, LOQ = 0.002, MDL = 0.001 target VXC analytes.  
 Comments: LOQ = 0.2, MDL = 0.05 @ 2 kg sample size

LOQ = Limit of Quantitation, MDL = method detection limit (lowest amount of analyte detected), Trace = impurity was below LOQ but above MDL, nd = indicates the impurity was not detected (below MDL), - = test not performed, % = percent, ppm = parts per million, ppb = parts per billion, v/v = vol. analyte/vol. sample, w/w = wt. analyte/wt. sample. Conversions: 1 ppm v/v = 1 μmol/mol (SI), 1 ppm w/w = 1 mg/kg (SI), VSC = target list volatile sulfur compounds, VXC = target list volatile halogenated (organic) compounds.

**Report Summary:** For the tests performed, this H<sub>2</sub> fuel sample meets all ISO 14687:2019 purity requirements.

Reviewed by / Date:

*Laboratory Manager mm/dd/yyyy*

Laboratory Manager  
 Attachments: None  
 Addendum: Signatures, Instrument & Notebook data on-file  
**ISO Statement**

Statement of conformity (pass or fail) resulting from the tests/analyses performed on the above sample will not take into account the reported measurement uncertainty unless otherwise specified. This is a shared risk decision rule to which the customer also has responsibility for determining acceptance of the results. The methods Airborne Labs International uses are developed by Airborne Labs International and are based on the current versions of international, national, or industry standards unless otherwise specified. Methods can be reviewed by the customer upon request. The acceptance criteria of the above-quoted items are based on IGBT specifications, NTPA, CGA, USP, or other industry specifications unless otherwise specified on the contract.



Accreditation # 68099

## COA Reports Can be Released

- Same Day as Received
- 1 Day / 2 Day / 3 Day
- Weekend/Holiday Service
- Std = 5 Working Days



# On-Line H<sub>2</sub> Analytical System (HyEx-2719)

(Designed for H<sub>2</sub> Fuel Producers + ISO-17025 accredited  
H<sub>2</sub> Analytical Laboratory Testing Operations)

- Employs ISO-14687:2019 / SAE-J2719 Recommended Methods and ISO-21087:2019(E) *Validated Equivalent* Analytical Methods (Validation Reports provided with this system)
- Highly automated & **Rapid** Analysis/Test Results With Quality Excursion Alarms
- **Customizable** for Specific H<sub>2</sub> Feed Gas Sources
- Can be used with 1L Cylinder or Transfer Line samples (ex. In-Process or Storage Tanks or Tube Trailers)








# H<sub>2</sub> Fuel On-Line Analytical System (HyEx-2719)

Customizable  
Configuration  
based on H<sub>2</sub>  
Feed source


DT Tray




Total Sulfur Pre-Concentrator Module



GC1 for; TSC, CO, CO<sub>2</sub>, Ar, O<sub>2</sub>, N<sub>2</sub>, CH<sub>4</sub>



DSA BlackBox Data Station: Sample CH Selection, Impurity List Data Display, System Control, COA Report Generation, QA Alarms, TSC, TNMHC, %H<sub>2</sub> Purity Calcs, Data log.



GC2 for; He, H<sub>2</sub>O, THC & others



GAS-2XLH = 2 Ch DT Analyzer: NH<sub>3</sub>, Halogens, Aldehydes, Organo / Halo-Acids etc.



AccuCal = Precision Dilution of Stock Stds to Working Cal Stds



ASCM-5H Gas Controller: Sample Ch or Gas Std Selection



H<sub>2</sub> Carrier Gas & Zero Air Generator



Power Conditioner / UPS



# Summary

- Proper H<sub>2</sub> Fuel Sampling is a **critical 1<sup>st</sup> step** in H<sub>2</sub> Purity Testing for proper Vehicle use.
- In all applications, a **Representative Sample** of the H<sub>2</sub> Fuel Must be taken. This is challenging for H<sub>2</sub> Fuel.
- The **Integrity** of the sample needs to be **preserved** from Time of Sampling to Final Analysis. **Short** time periods desired.
- **Several types** of Sampling Systems are available (ex. Gas Serial & Parallel) Each with advantages / disadvantages
- **Sampling Applications:** H35/H70 Refueling Stations, Vehicle Tanks, Bulk Storage Tanks, Pipelines, Plant Transfer Lines, In-Process Plant points, Tube Truck Loads.
- **Proper Hazmat Sample shipping** (when needed) is required.
- **Analysis** by an ISO accredited Lab using validated methods and fast result turn-around is required
- Development of **Economical, Effective, On-Site H<sub>2</sub> Fuel Analyzers** for use at H<sub>2</sub> Fuel Manufacturers and point-of-use refueling sites is the **next step** in assuring Spec. Grade H<sub>2</sub> Fuel.



# Thank You – Questions?

## Authors

- Mark R. Taylor, President
  - [Mark.Taylor@airbornelabs.com](mailto:Mark.Taylor@airbornelabs.com)
- Don Pachuta, Ph.D., CEO
  - [Don.Pachuta@airbornelabs.com](mailto:Don.Pachuta@airbornelabs.com)
- Chandler Stryker, Technical Sales
  - [Chandler.Stryker@airbornelabs.com](mailto:Chandler.Stryker@airbornelabs.com)



www.Airbornelabs.com  
1-732-302-1950

## • Airborne World-Wide Offices & Distributors

- Angola
- Brazil
- China
- France
- India
- Israel
- Pakistan
- Philippines
- South Africa
- Russia
- Taiwan
- Thailand
- United Arab Emirates
- United States of America
- **Poland**



*A special thanks to Sarah Pascoal, ALI Sales & Marketing Agent for her contributions to this paper*

*Note: NSP-7606/JSM-7606/MRM-7650 are trademarks of ALI & SilcoNert is a trademark of SilcoTech, NA*